



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

**Items with GA* are
clouded in RED
below (Rev. A)**

本署檔號 : (12) in WSD 3321/19 Pt.1 T/J(139)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 September 2019

**Approval of “VICTAULIC STRENGTHIN TM100”
Stainless Steel Fittings
(General Acceptance No. C20190474)**

Your letter dated 24 January 2019 and subsequent submission received by this department on 11 September 2019 refer.

Having considered the test report ref. 181058EN180927F issued on 6 September 2019 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Victaulic

Country of Origin: Poland

Brand: Victaulic StrengThin TM100

Details of Fittings: Stainless steel fittings with grooved type connection (304/304L)

Description	Model	Size (mm)
45° Elbow	E491	50, 65, 80, 100
90° Elbow	E490	50, 65, 80, 100
Concentric Reducer	E495	65x50, 80x50, 80x65, 100x50, 100x65, 100x80



香港環境卓越獎
Hong Kong Awards for Environmental Excellence



Description	Model	Size (mm)
Reducing Tee	E493	65x65x50, 80x80x50, 80x80x65, 100x100x50, 100x100x65, 100x100x80
Tee	E492	50, 65, 80, 100
Coupling	E497	50, 65, 80, 100

Body Markings:

 **STRENGTHIN** 100 size model

Expiry Date:

30 May 2024

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHEUNG Yip-kui)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only