



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/18 Pt.1 T/J(1186)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

12 December 2018

**Approval of “LAWTON” Copper Pipes
(General Acceptance No. A20180012)**

Your letter ref. SL20181005 dated 15 October 2018 and subsequent submission received by this department on 23 November 2018 refer.

The licence no. KM 05892 has been examined. It is noted that the British Standards Institution (BSI) has granted The Lawton Tube Company Limited the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on the Kitemark certificate and test report ref. BC-SUMMARY-2018-118 issued on 14 November 2018 by Castco Testing Centre Limited.

Name of Manufacturer: The Lawton Tube Company Limited

Country of Origin: UK

Brand: Lawton

Details of Pipes: Copper pipes (Type X)

Temper	Size (mm)
R250	15x0.7, 22x0.9, 28x0.9
R290	35x1.0, 42x1.0, 54x1.2, 66.7x1.2, 76x1.5, 108x1.5

Body Markings:

BS EN 1057  LAWTON O/D WALL I-I-I
MONTH YEAR

Expiry Date:

11 December 2021

In view of BSI granting licence to The Lawton Tube Company Limited on BS EN 1057 "Copper and copper alloys. Seamless, round copper tubes for water and gas in sanitary and heating applications" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the fresh water plumbing systems in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only