



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1212)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

16 January 2019

**Approval of "HATTERSLEY" Gate Valve
(General Acceptance No. A20190005)**

Your letters dated 29 October 2018 and 26 November 2018 refer.

The licence no. KM 509363 has been examined. It is noted that the British Standards Institution (BSI) has granted Crane Fluid & Gas Systems (Suzhou) Co Ltd the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the fitting described below based on the Kitemark certificate and test report ref. MS0180523-19 to 21, MS0180807-16 issued on 14 September 2018 by Castco Testing Centre Limited.

Name of Manufacturer: Crane Fluid & Gas Systems (Suzhou) Co Ltd

Country of Origin: the Mainland of China

Brand: Hattersley

Details of Fitting: 2½" Copper alloy gate valve

Model: Fig. 33X

Body Markings: Size, **HNH**, PN on body.
♥, temp, model on hand wheel.

Expiry Date: 15 January 2022

In view of BSI granting licence to Crane Fluid & Gas Systems (Suzhou) Co Ltd on BS EN 12288 "Copper alloy gate valves" as mentioned above, approval is hereby given to the said water supply fitting to be used in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply fitting if it is found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Fig. 33X