



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (3) in WSD 3321/19 Pt.1 T/J(42)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

6 March 2019

**Approval of “YUE HING” Hydrant Valves
(General Acceptance No. A20190009FS)**

Your letter ref. WSD/AP-16012019-1 dated 16 January 2019 refers.

The licence no. KM 650015 has been examined. It is noted that the British Standards Institution (BSI) has granted Yue Hing Machine Factory Ltd. the right and licence to use the Kitemark for goods as set out below.

Name of Manufacturer: Yue Hing Machine Factory Ltd
Country of Origin: Taiwan, China
Brand: Yue Hing
Details of Fitting: 3" Fire hydrant globe valve
Model: Y106X and Fig.805
Body Markings:   BS5041/1 LP/HP KM650015 size
Expiry Date: 5 March 2022

Proviso: The fittings can only be used in fresh water fire service plumbing systems.

In view of BSI granting licence to Yue Hing Machine Factory Ltd on BS 5041-1:1987 "Fire Hydrant Systems Equipment Landing Valves" as mentioned above, approval is hereby given to the said water supply fittings to be used on fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply fittings if they are found afterwards not suitable for use in the fresh water fire service plumbing systems in terms of quality or unacceptability of material.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Y106X



FIG.805