



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/19 Pt.1 T/J(195)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 May 2019

**Approval of “JSAW JAL” Ductile Iron Pipes
(General Acceptance No. A20190010)**

Your letters ref CHID/WSD/GA/JSAW/19/01, CHID/WSD/GA/JSAW/19/02 and CHID/WSD/GA/JSAW/19/03 dated 14 February 2019, 8 March 2019 and 25 March 2019 respectively refer.

The licence no. KM 516250 has been examined. It is noted that the British Standards Institution (BSI) has granted Jindal Saw Limited the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on Kitemark certificate and WRAS certificate comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jindal Saw Limited

Country of Origin: India

Brand: JSAW JAL

Details of Pipes: Ductile iron pipes with push in flexible joints (Class C and K) with internal cement mortar lining under WRAS approval no. 1610547

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm

Body Markings: JSAW JAL BS EN 545 size in DN

Expiry Date: 31 October 2021

In view of BSI granting licence to Jindal Saw Limited on BS EN 545 "Ductile iron pipes, fittings, accessories and their joints for water pipelines" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only