



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2020 T/J(934/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 October 2020

**Approval of "SEASTAR" Copper Pipes
(General Acceptance No. A20200011)**

Your letters dated 27 July 2020 and 8 October 2020 refer.

The licence no. KM 91198 has been examined. It is noted that the British Standards Institution (BSI) has granted Zhejiang Hailiang Co Ltd the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on the Kitemark certificate and test report ref. AMA01063 issued on 29 September 2020 by ETS-Testconsult Ltd comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Hailiang Co Ltd

Country of Origin: the Mainland of China

Brand: Seastar

Details of Pipes: Copper pipes (Type X)

Temper	Size (mm)
R250	15x0.7, 22x0.9, 28x0.9
R290	35x1.2, 42x1.2, 54x1.2, 66.7x1.2, 76.1x1.5, 108x1.5, 133x1.5, 159x2.0

Copper pipes (Type Y)

Temper	Size (mm)
R250	15x1.0, 22x1.2, 28x1.2
R290	35x1.5, 42x1.5, 54x2.0

Body Markings: BS EN 1057 Dia x Wall Temper Brand Year/Month

Expiry Date: 18 May 2023

In view of BSI granting licence to Zhejiang Hailiang Co Ltd on BS EN 1057 "Copper and copper alloys. Seamless, round copper tubes for water and gas in sanitary and heating applications" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the fresh water plumbing systems in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only