



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2020 T/J(823/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 November 2020

**Approval of "ELECTROSTEEL" Ductile Iron Pipes
(General Acceptance No. A20200014)**

Your letters dated 9 July 2020 and 14 October 2020 refer.

The licence no. KM 39560 has been examined. It is noted that the British Standards Institution (BSI) has granted Electrosteel Castings Limited the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on Kitemark certificate and WRAS certificate comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Electrosteel Castings Limited

Country of Origin: India

Brand: Electrosteel

Details of Pipes: Ductile iron pipes with push in flexible joints (Class C and K) with internal epoxy seal coat (under WRAS approval no. 1803512) for cement mortar lining (under WRAS approval no. 2010505)

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm,
350mm, 400mm, 450mm, 500mm, 600mm

Body Markings: BSEN545 Electrosteel  

Expiry Date: 31 March 2023

In view of BSI granting licence to Electrosteel Castings Limited on BS EN 545 "Ductile iron pipes, fittings, accessories and their joints for water pipelines" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the fresh water plumbing systems in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only