



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2021 T/J(707/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

29 June 2021

**Approval of “tub-e” Copper Fittings
(General Acceptance No. A20210007)**

Your letter ref. BK2021-VM-1082 dated 3 May 2021 refers.

The licence no. KM 670373 has been examined. It is noted that the British Standards Institution (BSI) has granted TM Autocast Co Ltd the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the fittings described below based on Kitemark certificate and test report ref. BC-SUMMARY-2021-056 issued on 16 April 2021 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: TM Autocast Co Ltd

Country of Origin: Thailand

Brand: tub-e

Details of Fittings: Copper alloy fittings with solder ring connection ends

Description	Model	Size
Female 90° Elbow	517	15x½", 22x½", 22x¾", 28x1" (mm x inch)
Male 90° Elbow	518	15x½" (mm x inch)

Description	Model	Size
Female Tee	507	15x15x $\frac{1}{2}$ ", 22x22x $\frac{1}{2}$ ", 35x35x $\frac{3}{4}$ ", 35x35x1", 42x42x $\frac{3}{4}$ ", 42x42x1", 54x54x $\frac{3}{4}$ ", 54x54x1" (mm x mm x inch)
Female Cross Tee	521	35x $\frac{3}{4}$ ", 35x1", 42x $\frac{3}{4}$ ", 42x1", 54x $\frac{3}{4}$ ", 54x1" (mm x inch)
Female Coupler	511	15x $\frac{1}{2}$ ", 22x $\frac{3}{4}$ ", 28x1", 35x1 $\frac{1}{4}$ ", 42x1 $\frac{1}{2}$ ", 54x2" (mm x inch)
Female Coupler (Reducer)	511	22x $\frac{1}{2}$ " (mm x inch)
Male Coupler	512	15x $\frac{1}{2}$ ", 22x $\frac{3}{4}$ ", 28x1", 35x1 $\frac{1}{4}$ ", 42x1 $\frac{1}{2}$ ", 54x2", (mm x inch)

Body Markings: tub-e

Expiry Date: 22 September 2023

In view of BSI granting licence to TM Autocast Co Ltd on BS EN 1254 / BS 864 Part 2 "Copper and copper alloy – Plumbing fittings" as mentioned above, approval is hereby given to the said water supply fittings to be used on fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply fittings if they are found afterwards not suitable for use in the fresh water plumbing systems in terms of quality or unacceptability of material.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.


c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Female 90° Elbow



Male 90° Elbow



Female Tee



Female Cross Tee



Female Coupler



Female Coupler
(Reducer)



Male Coupler