



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2021 T/J(788/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 July 2021

Dear Sirs,
Reference is made to your letter of 17 May 2021 regarding the proposed use of PAM ductile iron pipes for the installation of water supply pipes in the proposed development at the site of the former Kowloon Central Prison, Kowloon.

**Approval of "PAM" Ductile Iron Pipes
(General Acceptance No. A20210008)**

Your letter ref. GWL/21/017 dated 17 May 2021 refers.

The licence no. KM 673208 has been examined. It is noted that the British Standards Institution (BSI) has granted Saint-Gobain Pipelines Co Ltd the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on Kitemark certificate and WRAS certificate comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Saint-Gobain Pipelines Co Ltd

Country of Origin: the Mainland of China

Brand: PAM

Details of Pipes: Ductile iron pipes with flexible joints (Class C) with internal cement mortar lining under WRAS approval no. 2103506

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm

Body Markings:**Expiry Date:**

5 August 2023

In view of BSI granting licence to Saint-Gobain Pipelines Co Ltd on BS EN 545 "Ductile iron pipes, fittings, accessories and their joints for water pipelines" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only