



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(290/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

25 May 2023

**Approval of “SEASTAR” Copper Pipes
(General Acceptance No. A20230011)**

Your letters dated 21 March 2023, 27 April 2023 and 12 May 2023 refer.

The licence no. KM 91198 has been examined. It is noted that the British Standards Institution (BSI) has granted Zhejiang Hailiang Co Ltd the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on the Kitemark certificate and test reports ref. AMA01063A issued on 25 April 2023 by ETS-Testconsult Ltd & ref. J28925A-C and J28926A-Cr1 issued on 25 April 2023 and 11 May 2023 by Nutek Systems (HK) Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Hailiang Co Ltd

Country of Origin: the Mainland of China

Brand: Seastar

Details of Pipes: Copper pipes (Type X)

Temper	Size (mm)
R250	15x0.7, 22x0.9, 28x0.9
R290	35x1.2, 42x1.2, 54x1.2, 66.7x1.2, 76.1x1.5, 108x1.5, 133x1.5, 159x2.0



香港環境卓越大樓
Hong Kong Awards for Environmental Excellence



Copper pipes (Type Y)

Temper	Size (mm)
R250	15x1.0, 22x1.2, 28x1.2
R290	35x1.5, 42x1.5, 54x2.0

Body Markings:

BS EN 1057  DIA x Wall TYPE
Temper Brand Year / Month

Expiry Date:

25 August 2024


In view of BSI granting licence to Zhejiang Hailiang Co Ltd on BS EN 1057 "Copper and copper alloys. Seamless, round copper tubes for water and gas in sanitary and heating applications" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the fresh water plumbing systems in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only