



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2024 T/J(112/2024)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

27 February 2024

**Approval of “TATA DUCTURA” Ductile Iron Fitting
(General Acceptance No. A20240007)**

Your letter ref. CYH-WSD-0033 dated 30 January 2024 refers.

The licence no. KM 639475 has been examined. It is noted that the British Standards Institution (BSI) has granted Tata Metaliks Limited (DI Pipe Division) the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the fitting described below based on Kitemark certificate and WRAS certificate complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tata Metaliks Limited (DI Pipe Division)

Country of Origin: the Mainland of China

Brand: Tata Ductura

Details of Fitting: Ductile iron fitting with internal epoxy powder coating under WRAS approval no. 2103504

Description	Size (mm)
All Socket Tee	450x450x300

Body Markings: DUCTURA

Expiry Date: 31 March 2026

In view of BSI granting licence to Tata Metaliks Limited (DI Pipe Division) on BS EN 545 "Ductile iron pipes, fittings, accessories and their joints for water pipelines" as mentioned above, approval is hereby given to the said water supply fitting to be used on fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply fitting if it is found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



All Socket Tee