



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(574/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 August 2024

**Approval of “EAGLE” Copper Pipes
(General Acceptance No. A20240019)**

Your letters dated 13 June 2024 and 9 July 2024 refer.

The licence no. KM 05526 has been examined. It is noted that the British Standards Institution (BSI) has granted Mueller Europe Limited T/A Yorkshire Copper Tube the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on the Kitemark certificate & test reports ref. J27495A-C and J28974A-Cr1 issued on 14 December 2021 and 5 July 2024 by Nutek Systems (HK) Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Mueller Europe Limited T/A Yorkshire Copper Tube

Country of Origin: UK

Brand: Eagle

Details of Pipes: Copper pipes (Type X)

Temper	Size (mm)
R250	15x0.7, 22x0.9, 28x0.9
R290	35x1.2, 42x1.2, 54x1.2, 66.7x1.2, 76.1x1.5, 108x1.5

Body Markings:

For Temper R250:

EAGLE UK B EN 1057 -X- od x wall
HH month / year

For Temper R290:

EAGLE UK B EN 1057 -X- od x wall
month / year**Expiry Date:**

12 December 2026

In view of BSI granting licence to Mueller Europe Limited T/A Yorkshire Copper Tube on BS EN 1057 "Copper and copper alloys. Seamless, round copper tubes for water and gas in sanitary and heating applications" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the fresh water plumbing systems in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only