



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail
wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile
2824 0578

檔號
Reference
(6) in WSD 3321/2024 T/J(1225/2024)

24 December 2024

**Approval of "LAWTON" Copper Pipes
(General Acceptance No. A20240037)**

Your letter ref. SL20241004-1 dated 4 October 2024 and subsequent submissions received by this department up to 27 November 2024 refer.

The licence no. KM 05892 has been examined. It is noted that the British Standards Institution (BSI) has granted The Lawton Tube Company Limited the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on Kitemark certificate and test report ref. BC-SUMMARY-2021-176 issued on 16 November 2021 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: The Lawton Tube Company Limited

Country of Origin: UK

Brand: Lawton

Details of Pipes: Copper pipes (Type X)

Temper	Size (mm)
R250	15x0.7, 22x0.9, 28x0.9, 35x1.2, 42x1.2, 54x1.2



Temper	Size (mm)
R290	66.7x1.2, 76x1.5, 108x1.5

Body Markings: BS EN 1057  LAWTON O/D
WALL I-I-I Month/Year

Expiry Date: 31 December 2026

In view of BSI granting licence to The Lawton Tube Company Limited on BS EN 1057 "Copper and copper alloy. Seamless, round copper tubes for water and gas in sanitary and heating applications" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the fresh water plumbing systems in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only