



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/17 Pt.1 T/J(96)

6 March 2017

Approval of “DELABIE” Self Closing Taps

Your letter ref. HK745 dated 7 February 2017 refers.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Delabie SCS

Country of Origin: France

Brand: Delabie

Details of Fitting: Self-closing tap assembly (chromium plated brass) with spring loaded headwork and dome type or single lever operating members. The outlet incorporates a plastic flow straightener. Supplied with metal or plastic backnuts depending on model. Maximum working pressure 5.0 Bar. Maximum operating temperature 60°C.

Model: For dome type:
745100, 745101, 745250, 745300, 745301 & 745351

For single lever:
745440 & 745450

Size: ½" BSP male inlets

Marking: For dome type operating members:
Delabie on operating member

For single lever models:
Delabie on body

WRAS Approval Number: 1607002

Installation Requirements: R001, R006

Expiry Date: 31 July 2021

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



745100



745101



745250



745440



745300



745301



745351



745450