



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(251)

27 March 2017

Approval of "HANSGROHE" Combination Tap Assembly

Your letters ref. HG/HK/WSD/013/03/17 and HG/HK/WSD/013/03/17 r1 dated 10 March 2017 and 16 March 2017 respectively refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Hansgrohe SE

Country of Origin: Germany


Brand: Hansgrohe

Details of Fitting: Wall mounted, two hole, bar type thermostatic blending valve (chromium plated brass) incorporating a half turn ceramic disc for diverting between bath/off/shower positions and a thermostatic cartridge controlling the temperature, both with dome type operating members. The product also incorporates a self-cancelling diverter to a shower handset. The spout outlet incorporates a plastic aerator. Each inlet incorporates a single check

valve cartridge (suitable for backflow protection against Fluid Category 2) and stainless steel strainers. Maximum working pressure 10.0 bar. Maximum operating temperature 60°C.

Model: 27117000

Size: ½" x ¾" offset unions

Marking:  on top of body,
 and product info on underside of body

WRAS Approval Number: 1611047

Installation Requirements: R001, R030

Expiry Date: 30 November 2021

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

“The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.” AND

“The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use.”

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



27117000