



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(6) in WSD 3321/17 Pt.1 T/J(503)

20 June 2017

Approval of "HANSGROHE" Combination Tap Assemblies

Your letters ref. HG/HK/WSD/028/05/17, HG/HK/WSD/028/05/17 r1 and HG/HK/WSD/028/05/17 r2 dated 5 May 2017, 19 May 2017 and 6 June 2017 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Hansgrohe SE

Country of Origin: Germany

Brand: Hansgrohe

Details of Fittings: Range of single hole, single outlet (fixed) combination tap assemblies (chromium plated brass), Incorporating a push on/off headwork with rotary temperature control using dome type lever operating member. Some models are supplied with lever type pop up waste. Inlets incorporate a single check valve cartridge (suitable for backflow protection against fluid category 2) and a

stainless steel strainer. The outlets incorporate a plastic aerator. Maximum working pressure 10.0 bar. Maximum operating temperature 60°C.

Model: 72040, 72041, 72042, 72043, 72044, 72045 & 71750

Size: Stainless steel braided P-EX lined hose with 3/8" BSP Captive nut

Marking: Hansgrohe on body

WRAS Approval Number: 1612014

Installation Requirements: R001, R006, R009

Expiry Date: 31 December 2021

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,




(CHAN Chung Kun)
for Water Authority


c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only




72040




72041




72042




72043



72044



72045



71750