



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(1106)

30 October 2017

Approval of “HATTERSLEY” Check Valves

Your letters dated 17 August 2017 and 18 October 2017 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Hattersley

Country of Origin: UK

Brand: Hattersley

Details of Fittings: Range of in-line non-verifiable single check valve assemblies consisting of a spring loaded resilient trim single check valve cartridge housed within a DZR brass body. Maximum working pressure 10.0 bar. Maximum operating temperature 60°C.

Model: FIG 150W & FIG 150CW

Size: For FIG 150W:
½", ¾", 1", 1¼", 1½", 2"

For FIG 150CW:
15mm, 22mm, 28mm

Marking: **HH**, CR, flow arrow & DN on body

WRAS Approval Numbers: 1707396

Installation Requirement: R001

Expiry Date: 31 July 2022

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



FIG 150W



FIG 150CW