



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/17 Pt.1 T/J(831)

9 January 2018

Approval of "VAG EKOPLUS" Gate Valves

Your letter ref. 170626 dated 26 June 2017 and subsequent submission received by this department on 14 December 2017 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: VAG Armaturen GmbH

Country of Origin: Czech Republic

Brand: VAG EKOplus

Details of Fitting: Range of gate valves with blue epoxy coated cast iron bodies, EPDM coated wedges and non-rising spindles with square tapered shaft operating members. Maximum working pressure 16.0 bar. Cold water use only. (with epoxy powder coating under WRAS approval no. 1701509)

Model: VAG EKOplus BS5163 Type B

Size: 50mm, 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

Marking: VAG, size, pressure rating and date of manufacture (mm/yyyy) on body

WRAS Approval Number: 1706076

Installation Requirements: R001

Expiry Date: 31 January 2022

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



VAG EKOpus BS5163 Type B