



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (10) in WSD 3321/17 Pt.1 T/J(703)

31 January 2018

Approval of “HONEYWELL” Pressure Reducing Valves

Your letter ref. GWL/17/00001 dated 13 June 2017 and subsequent clarification by email on 11 January 2018 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Honeywell GmbH

Country of Origin: Germany

Brand: Honeywell

Details of Fittings: Range of in-line manually adjustable pressure reducing valves with blue epoxy coated cast iron bodies, stainless steel cartridges, EPDM rubber diaphragm and seals. The outlet pressure is adjusted via a 24mm hexagonal spindle located on the top of the valve. Maximum working pressure 16.0 bar. Maximum outlet pressures: 1.5 - 6.5 bar. Cold water use only.

Model & Size: D15SI-65A - 65mm
D15SI-80A - 80mm
D15SI-100A - 100mm

Marking: Honeywell, model number, DN size, PN 16, EN-GJS-400-15 and flow arrow etched on body.
Model number, maximum working temperature, WRAS, Honeywell and made in Germany on adhesive label on body.

WRAS Approval Numbers: 1702051

Installation Requirement: R001, R120

Expiry Date: 28 February 2022

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



D15SI-65A / D15SI-80A / D15SI-100A