



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/18 Pt.1 T/J(39)

8 March 2018

Approval of "SINGER VALVE" Pressure Relief Valves

Your letter ref. WTD/MRT-L001/17 dated 14 August 2017 and subsequent submission received by this department on 23 February 2018 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Singer Valve Inc

Country of Origin: Canada

Brand: Singer Valve

Details of Fittings: Range of in-line pilot operated control valves with blue epoxy coated ductile iron bodies, having pressure relief control facility controlled via a pilot valve. Maximum working pressure 25.0 bar. Outlet pressure 0.34-20.68 bar. Spring ratings of pilot valve are 0.34-3.44 bar, 0.68-5.51bar; 1.37-13.79 bar & 6.89-20.68 bar. Maximum operating temperature 65°C. (with epoxy powder coating under WRAS approval no. 1701509)

Model: 106-RPS

Size: 40mm, 50mm, 65mm, 80mm, 100mm, 150mm, 200mm

Marking: Singer name, flow arrow, size & material code on body. Singer, model number and pressures on data plate on body.

WRAS Approval Numbers: 1702353

Installation Requirement: R001

Expiry Date: 31 January 2022

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.


For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



106-RPS