



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/17 Pt.1 T/J(903)

16 March 2018

Approval of "VAG" Butterfly Valves

Your letter ref. EKN.170703 dated 3 July 2017 and subsequent submission received by this department on 5 March 2018 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: VAG Armaturen GmbH

Country of Origin: China

Brand: VAG

Details of Fitting: Range of 'EKN' butterfly valves (hand wheel operation) with an epoxy coated ductile iron body, EPDM seat and stainless steel disc. Maximum working pressure 16.0 bar. Cold water use only. (with epoxy powder coating under WRAS approval no. 1701509)

Model: VAG EKN range

Size: 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm

Marking: 'VAG', size and PN rating located on label on valve body.

WRAS Approval Number: 1612047

Installation Requirements: R001

Expiry Date: 31 December 2021

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



VAG EKN range