



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/18 Pt.1 T/J(374)

28 May 2018

Approval of “VADO” Combination Tap Assemblies

Your letter ref. L18-023 dated 16 April 2018 and subsequent submission received by this department on 16 May 2018 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test report ref. J22831Ar1 issued on 11 May 2018 by Nutek Systems (HK) Limited.

Name of Manufacturer: Vado

Country of Origin: UK

Brand: Vado

Details of Fittings: Range of single hole, single outlet (fixed) combination tap assemblies (chromium plated brass) incorporating ceramic cartridge headworks, waterfall type spout outlet and single lever operating members. Models ORI-200/SB-C/P & ORI-200/CC-C/P incorporate a plastic aerator. The products are supplied with a click

waste. Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.

Model: ORI-200/SB-C/P and ORI-200/CC-C/P

Size: Stainless steel braided FLX lined hose assembly with ½” captive nut

Marking:  on body

WRAS Approval Number: 1801332

Installation Requirements: R001, R006, R009, R010, R160

Expiry Date: 31 January 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



ORI-200/SB-C/P



ORI-200/CC-C/P