



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 4 ) in WSD 3321/18 Pt.1 T/J(765)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

16 August 2018

**Approval of “HATTERSLEY” Check Valves  
(General Acceptance No. B20180040)**

Your letters dated 6 July 2018 and 19 July 2018 refer.

It is noted that the fittings described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test reports ref. MS0180320-50, MS0180320-51 and MS0180320-52 issued on 9 May 2018 & MS0180320-55, MS0180320-56 and MS0180320-57 issued on 19 April 2018 by Castco Testing Centre Limited.

**Name of Manufacturer:** Hattersley

**Country of Origin:** China

**Brand:** Hattersley

**Details of Fittings:** Range of swing gate non-return valves (resilient trim) with bronze bodies, brass swing gate with nitrile rubber gasket. Maximum working pressure 25.0 bar. Maximum operating temperature 85°C.

**Model:** Fig. 3047W

**Size:** ¾", 1", 1¼, 1½, 2"

**Body Markings:** HNH, SIZE, FLOW ARROW & PN ON BODY

**WRAS Approval Number:** 1806070

**Installation Requirements:** R001

**Expiry Date:** 30 June 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(WONG Yan-lok, Roger)  
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only

---

**General Acceptance No. B20180040**



Fig. 3047W