



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1095)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

10 December 2018

**Approval of “ARMITAGE SHANKS” Manual Blending Valve
(General Acceptance No. B20180073)**

Your letter ref. L18-073 dated 27 September 2018 and subsequent clarification by email on 22 November 2018 refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate and test report ref. J23535 issued on 24 September 2018 by Nutek Systems (HK) Limited.

Name of Manufacturer: Ideal Standard (UK) Ltd

Country of Origin: UK

Brand: Armitage Shanks

Details of Fitting: ‘Avon 21’ wall mounted concealed shower valve with cast brass body (chromium plated trim) & EDPM ‘O’ rings incorporating a self-closing, spring loaded headwork with dome operating member controlling the flow and temperature. Inlets incorporate stainless steel filters and single check valve cartridges (suitable for backflow protection against Fluid Category 2). Maximum

working pressure 10.0 bar. Maximum operating temperature 85°C.

Model: B8266AA

Size: 1/2" BSP female inlets x outlets

Body Markings: *Armitage Shanks* located on operating member

WRAS Approval Number: 1704700

Installation Requirements: R001, R010, R040

Expiry Date: 30 April 2022

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

“The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.” AND

“The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use.”

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



B8266AA