



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/18 Pt.1 T/J(1297)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

25 February 2019

**Approval of "VADO" Combination Tap Assembly
(General Acceptance No. B20190020)**

Your letters ref. L18-097, L18-097R1 and L18-097R2 dated 22 November 2018, 31 January 2019 and 11 February 2019 respectively refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Vado

Country of Origin: UK

Brand: Vado

Details of Fitting: Range of deck mounted, electronically operated combination tap assembly (chromium plated brass). The flow is controlled by a solenoid valve which is actuated via an infrared sensor on the spout. The product is supplied with a nylon braided, PVC lined flexible connecting hose. Maximum working pressure 8.0 bar. Maximum operating temperature 60°C.

Model: IR-DSPOUT-C/P



Size: 1/2" BSP (M)

Body Markings:  on tap body

WRAS Approval Number: 1805364

Installation Requirements: R001, R006, R007

Expiry Date: 31 May 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

“A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply.” AND

“The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc.”

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



IR-DSPOUT-C/P