



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 Pt.1 T/J(278)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 May 2019

**Approval of “TUCAI” Flexible Hoses
(General Acceptance No. B20190036)**

Your letters both ref. SL20190320_Tucaí dated 20 March 2019 and 6 May 2019 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Ningbo Tucai Flexible Pipe Co Ltd

Country of Origin: the Mainland of China

Brand: Tucai

Details of Fitting: Range of stainless steel EPDM lined hose assemblies with various end connections. Maximum working pressure 10.0 bar. Maximum operating temperature 95°C.

- Model and Size:**
1. TAQ MINI
Bore diameter: DN6
End connections: M10, M15, M15 captive nut, 3/8" captive nut, 1/2" captive nut, pipe end 10mm (LISO 10)
 2. TAQ FORTE
Bore diameter: DN11
End connections: M12, 1/2" & 3/4" captive nut, 1/2" BSP, 3/4" BSP and 15mm compression
 3. TAQ SUPER
Bore diameter: DN13
End connections: 1/2" captive nut, 3/4" captive nut, 1/2" BSP, 3/4" BSP, pipe end 15mm, pipe end 22mm
- Body Markings:** Tucai, WRAS, date of manufacture (YY) on crimp connection

WRAS Approval Number: 1710343

Installation Requirements: R001

Expiry Date: 31 October 2022

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The inlet flexible hose is applied for the water tap or mixer connection only and installed in the fresh water plumbing systems.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



TAQ MINI



TAQ SUPER



TAQ FORTE