



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/19 T/J(550/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

5 November 2019

**Approval of "NEOPERL" Flexible Hose
(General Acceptance No. B20190061)**

Your letter ref. L19-055 dated 5 June 2019 and subsequent submission received by this department on 10 October 2019 refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Neoperl Iberica SA

Country of Origin: Spain

Brand: Neoperl

Details of Fitting: 'One4All' range of stainless steel braided flexible hose assemblies incorporating polyethylene liners. Models may also incorporate EPDM 'O'-rings and washers. The hoses are available with a variety of end connections. Maximum working pressure 10.0 bar. Maximum operating temperature 70°C.

Model:	One4All Range
Size:	Bore diameters: DN6 & DN8 End connections: $\frac{3}{8}$ ", $\frac{1}{2}$ " & $\frac{3}{4}$ " captive nut M10 & M12 male thread $\frac{3}{8}$ " & $\frac{1}{2}$ " BSP (M) 10mm & 15mm compression 10mm & 15mm spigot
Body Markings:	IM (abbreviation of Industrias Mateu which is a brand of Neoperl Iberica SA), DN size, date of manufacture (MM/YY) and WRAS on ferrule
WRAS Approval Number:	1811042
Installation Requirements:	R001, R008
Expiry Date:	30 November 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The inlet flexible hose is applied for the water tap or mixer connection only and installed in the fresh water plumbing systems.”

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



One4All Range