



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (12) in WSD 3321/19 Pt.1 T/J(374)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 November 2019

**Approval of “OR” Pressure Reducing Valves
(General Acceptance No. B20190065)**

Your letter ref. WSD/AP-15042019-1 dated 15 April 2019 and subsequent clarifications by email on 14 November 2019 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test reports ref. 175495PC180027C, 175495PC180027(1)C, 175495PC180027(2)C, 175495PC180027(3)C, 175495PC180027(4)C & 175495PC180027(5)C all issued on 15 October 2019 by Fugro Technical Services Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Officine Rigamonti Spa

Country of Origin: Italy

Brand: OR

Details of Fittings: Range of inline manually adjustable pressure reducing valves with brass bodies (½” - 2” models) or bronze bodies (2½” - 4” models), EPDM seat washers and ‘O’-rings. Minimum and maximum regulated outlet

pressures 1-7 bar. Maximum working pressure 40.0 bar, Maximum operating temperature 80°C.

Model & Size:

Model	Size
Art 229.015	1/2"
Art 229.025	1"
Art 229.033	1 1/4"
Art 229.042	1 1/2"
Art 229.050	2"
Art 229.066	2 1/2"
Art 229.080	3"
Art 229.100	4"

Body Markings:

OR , CR, pressure, size and date of manufacture (MM/YY) on body

WRAS Approval Number: 1707358

Installation Requirements: R001, R120

Expiry Date: 31 July 2022

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Art 229.015 / Art 229.025 / Art 229.033 /
Art 229.042 / Art 229.050 / Art 229.066 /
Art 229.080 / Art 229.100