



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/19 T/J(961/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

24 December 2019

**Approval of “NEOPERL” Flexible Hose
(General Acceptance No. B20190071)**

Your letter ref. 010/kl dated 12 September 2019 and subsequent submissions received by this department up to 9 December 2019 refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Neoperl GmbH

Country of Origin: Germany

Brand: Neoperl

Details of Fitting: Range of polyamide (PA) braided PEX lined flexible hose assemblies with brass end connections, EPDM washers and fibre washers. Maximum working pressure 10.0 bar. Maximum operating temperature 70°C.

Model:	39.00CD.EFG.HI (where CD.EFG = hose specification including fitting specification (00.000 – 99.999) and HI = Packaging information (0-9))
Size:	Bore diameters: DN6 & DN8 End connections: Female elbow (BSP captive nut): 3/8", 1/2", 3/4" Female (BSP captive nut): 3/8", 1/2", 3/4" Tube: 10mm to 12mm Male (BSP): M10 to M15 Male (BSP): 3/8", 1/2", 3/4" Comp. joint: ø10 - ø15 Plugin: D10- D13
Body Markings:	Neoperl, Softpex, WRAS and date of manufacture (YYMMDD) on crimped connector
WRAS Approval Number:	1904348
Installation Requirements:	R001, R008
Expiry Date:	30 April 2024

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The inlet flexible hose is applied for the water tap or mixer connection only and installed in the fresh water plumbing systems.”

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



39.00CD.EFG.HI