



48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

電話
Tel.
傳真
Fax

7 April 2020

Approval of “MALGORANI” Pressure Reducing Valves (General Acceptance No. B20200025)

Your letters ref. WSD-143-19-L003, WSD-143-19-L004 and WSD-143-19-L005 dated 16 December 2019, 14 January 2020 and 6 March 2020 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test report ref. 191426PC190182A issued on 8 January 2020 by Fugro Technical Services Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Rubinetteria Malgorani Pietro Srl

Country of Origin: Italy

Brand: Malgorani

Details of Fittings: 'Eurobrass 143' range of adjustable in-line pressure reducing valves with DZR brass bodies and diaphragms, incorporating EPDM seals and stainless-steel seats.



Maximum supply pressure 25.0 bar. Outlet pressure setting is adjustable in the range 2.5 to 6.0 bar. Maximum operating temperature 80°C.

Model: Eurobrass 143

Size: ½", ¾", 1", 1¼", 1½", 2"

Body Markings: Eurobrass Blu PN 25, Max pressure and temperature on adhesive label. Flow arrow, made in Italy, CR and  on body

WRAS Approval Number: 1901801

Installation Requirements: R001, R120

Expiry Date: 31 January 2024

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Eurobrass 143