



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2020 T/J(762/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

20 July 2020

**Approval of “NEOPERL” Flexible Hose
(General Acceptance No. B20200047)**

Your letters all ref. 012-rk dated 22 June 2020, 30 June 2020 and 6 July 2020 refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Neoperl GmbH

Country of Origin: Germany

Brand: Neoperl

Details of Fitting: Range of stainless steel braided, PEX lined hoses incorporating various brass end connection configuration options. Maximum working pressure 10.0 bar. Maximum operating temperature 70°C.

Model: 39.00CD.EFG.HI Softpex® range
(where CD.EFG = Manufacturing sequential number and HI =Packaging information)

Size: Bore diameters:
DN6 & DN8

End connections:
Female elbow: 3/8", 1/2", 3/4"
Female: 3/8", 1/2", 3/4"
Tube: ø10 - ø12
Male: M10, M12, M15
Male: 3/8", 1/2", 3/4"
Comp. joint: ø10 - ø15
Plugin: D10- D13

Body Markings: Neoperl, SPX, 70°C, 10bar, DN, size & date of manufacture (YYMMDD) on end connection.

WRAS Approval Number: 2005316

Installation Requirements: R001, R008

Expiry Date: 31 May 2025

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The inlet flexible hose is applied for the water tap or mixer connection only and installed in the fresh water plumbing systems.”

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



39.00CD.EFG.HI Softpex® range