水 務 署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : (6) in WSD 3321/2020 T/J(1452/2020)
來函檔號 *Your ref.* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

23 February 2021

Approval of "DELABIE" Basin Mixer
(General Acceptance No. B20210006)

Your letters all ref. 2446L dated 4 November 2020, 21 December 2020 and 18 January 2021 refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate and test report ref. J25477 issued on 15 October 2020 by Nutek Systems (HK) Limited complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Delabie SCS

Country of Origin: France

Brand: Delabie

Details of Fitting: Range of wall mounted, two-hole, single outlet (swivel) combination tap assemblies (chromium plated brass), incorporating ceramic cartridge headwork with single lever operating members. Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.

香港環境卓越大獎 Hong Kong Awards for Environmental Excellence
10 years+ 同心當幫意 caringorganisation

Model: 2446L

Size: 1/2"

Body Markings: Delabie on operating member

WRAS Approval Number: 2101700

Installation Requirements: R001, R010, R040

Expiry Date: 23 December 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

> "Installation shall comply with the 'Installation Requirements & Notes' of the WRAS's approval letter concerned." AND
>
> "The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



2446L