水 務 署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : (4) in WSD 3321/2021 T/J(45/2021)
來函檔號 *Your ref.* :
電話 *Tel.* :
傳真 *Fax.* : 2824 0578

8 March 2021

Approval of "MEIDE" Gate Valve
(General Acceptance No. B20210008)

Your letters dated 16 December 2020 and 10 February 2021 refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate and test report ref. AMA90567A issued on 8 February 2021 by ETS-Testconsult Ltd. complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jinan Meide Casting Co Ltd

Country of Origin: the Mainland of China

Brand: Meide

Details of Fitting: 'Z45X' range of gate valves with blue epoxy coated ductile iron bodies incorporating non-rising spindles, NBR 'O'-rings, EPDM seal and/or gasket and a ductile iron wedge encapsulated in EPDM. Maximum working pressure 16.0 bar. Maximum operating temperature 80°C.

(with epoxy powder coating under WRAS approval no. 1901506)

Model: Z45X

Size: 65mm

Body Markings:  , size and DI on body. Model, batch no. and date of manufacture (YY MM DD) on data plate on body.

WRAS Approval Number: 1809330

Installation Requirements: R001

Expiry Date: 30 September 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

> "Installation shall comply with the 'Installation Requirements & Notes' of the WRAS's approval letter concerned."

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Z45X