水 務 署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : (2) in WSD 3321/2021 T/J(257/2021)
來函檔號 *Your ref.* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

10 March 2021

Approval of "VADO" Basin Mixer
(General Acceptance No. B20210013)

Your letter ref. L21-015 dated 27 January 2021 refers.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate and test report ref. RGTC081 issued on 21 January 2021 by Ideal Test Consultants Limited complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Vado
Country of Origin:	UK
Brand:	Vado
Details of Fitting:	Range of single hole, single outlet (fixed) combination tap assemblies (chromium plated brass). Incorporating ceramic cartridge headworks, and single lever operating members. Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.
Model:	LIF-200/SB-CP

香港環境卓越大獎 Hong Kong Awards for Environmental Excellence
10 years+ 關心機構 caringorganisation

Size: 1/2"

Body Markings: VADO on body

WRAS Approval Number: 2001308

Installation Requirements: R001, R006, R009, R010

Expiry Date: 31 January 2025

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

> "Installation shall comply with the 'Installation Requirements & Notes' of the WRAS's approval letter concerned." AND
>
> "The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



LIF-200/SB-CP