



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2020 T/J(1551/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

8 April 2021

**Approval of “DOROT” Pressure Reducing Valves
(General Acceptance No. B20210023FS)**

Your letters ref. AWSD0003/20, AWSD0003/20(2) and AWSD0003/20(3) dated 26 November 2020, 15 January 2021 and 8 March 2021 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Dorot Management Control Valves Ltd

Country of Origin: Israel

Brand: Dorot

Details of Fitting: Series ‘500’ range of pilot operated pressure reducing valves with ductile iron bodies (blue polyester or epoxy coating) and EPDM diaphragm. Maximum working pressure 16.0 bar. Cold water use only.

Model: Series 500

Size: 2", 2½, 3", 4", 6", 8"

Body Markings: 'Dorot', size and flow arrow on valve body. Model, date of manufacture and PN rating located on metal plate on valve body.

WRAS Approval Number: 1609109

Installation Requirements: R001

Expiry Date: 31 August 2021

Proviso: The fittings can only be used in fresh water fire service systems.

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Series 500