



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2021 T/J(803/2021)
Our ref.
來函檔號 :
Your ref

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 July 2021

**Approval of "TUCAI" Flexible Hose
(General Acceptance No. B20210037)**

Your letters all ref. TAQ PEX DN6 dated 18 May 2021, 18 June 2021 and 28 June 2021 refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Ningbo Tucai Flexible Pipe Co Ltd

Country of Origin: the Mainland of China

Brand: Tucai

Details of Fitting: Range of stainless steel braided PEX lined flexible hose assembly. Maximum working pressure 10.0 bar. Maximum operating temperature 85°C.

Model: TAQ PEX DN6

Size: Bore diameters:
DN6

End connections:

M10x1, M15x1, M15x1 captive nut, 3/8" captive nut, 1/2" captive nut, pipe end 10mm (LISO 10), M11x1, M12x1, compression fitting 10mm, compression fitting 15mm, 3/8" BSP

Body Markings: Tucai, WRAS, year of manufacture (YY), manufacturing company (NT) on ferrule.

WRAS Approval Number: 2012802

Installation Requirements: R001, R008

Expiry Date: 31 December 2025

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The inlet flexible hose is applied for the water tap or mixer connection only and installed in the fresh water plumbing systems.”

A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.


Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



TAQ PEX DN6