



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/2021 T/J(796/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 August 2021

**Approval of “GIACOMINI” Spherical Valves
(General Acceptance No. B20210040FS)**

Your letter dated 24 May 2021 and subsequent submissions received by this department up to 20 July 2021 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test report ref. J26505A-F issued on 13 May 2021 by Nutek Systems (HK) Ltd. comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Giacomini SpA

Country of Origin: Italy

Brand: Giacomini

Details of Fitting: Range of lever operated spherical valves with chrome plated brass bodies incorporating brass balls and PTFE seats. Maximum working pressure 35.0 bar. Maximum operating temperature 60°C.

Model: R250D

Size: $\frac{1}{2}$ ", $\frac{3}{4}$ ", 1", $1\frac{1}{4}$ ", $1\frac{1}{2}$ ", 2"

Body Markings: For size $\frac{1}{2}$ " to 1":
 size in DN ITALY Production date size in inch

For size $1\frac{1}{4}$ " to 2":
 CE ITALY Production date size in inch

WRAS Approval Number: 1907332

Installation Requirements: R001

Expiry Date: 31 July 2024

Proviso: The fittings can only be used in fresh water fire service systems.

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only

General Acceptance No. B20210040FS



R250D