



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 7 ) in WSD 3321/2021 T/J(862/2021)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

19 October 2021

**Approval of "HATTERSLEY" Strainers  
(General Acceptance No. B20210042)**

Your letter dated 31 March 2021 and subsequent submissions received by this department up to 20 September 2021 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificates and test reports ref. MS0180807-17, MS0180807-18 and MS0180807-19 all issued on 23 August 2018 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Hattersley

**Country of Origin:** the Mainland of China

**Brand:** Hattersley

**Details of Fitting:** Range of 'Y' patterned in-line strainers with blue epoxy coated cast iron bodies and stainless steel strainers. Maximum working pressure 16.0 bar. Maximum

operating temperature 85°C. (with epoxy coating under WRAS approval no. 2104506)

**Model:** Fig.816W

**Size:** 65mm, 80mm, 100mm, 125mm, 150mm

**Body Markings:** **HH**, operating details on data plate. Imperial size & year of manufacture YYYY & DN on body.

**WRAS Approval Number:** 1811060

**Installation Requirements:** R001, R120

**Expiry Date:** 13 August 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)  
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



Fig 816W