



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1497/2021)
Our ref.
來函檔號 :
Your ref

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 November 2021

**Approval of “HATTERSLEY” Strainers
(General Acceptance No. B20210045)**

Your letters dated 29 September 2021 and 27 October 2021 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test report ref. AMA11033 issued on 30 July 2021 by ETS-Testconsult Ltd. comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hattersley

Country of Origin: the Mainland of China

Brand: Hattersley

Details of Fitting: Range of Hattersley ‘Y’-patterned strainers with bronze bodies incorporating a stainless steel mesh strainer and PTFE washers. Maximum working pressure 16.0 bar. Maximum operating temperature 85°C.

Model: Fig 817

Size: $\frac{1}{2}$ ", $\frac{3}{4}$ ", 1", $1\frac{1}{4}$ ", $1\frac{1}{2}$ ", 2"

Body Markings: HNH, size, PN and flow arrow on body. HATETRSLY, WRAS, temperature, max temperature/pressure and other technical info on strainer cap.

WRAS Approval Number: 1910704

Installation Requirements: R001, R120

Expiry Date: 31 October 2024

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Fig 817