



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1684/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

31 January 2022

**Approval of "AQUAPOWER" Gate Valves
(General Acceptance No. B20220002)**

Your letters ref. AP/021/BY/2021 and AP/001/BY/2022 dated 17 November 2021 and 10 January 2022 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test report ref. 206658PC210001A issued on 3 January 2022 by Fugro Technical Services Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SLK Manufacturing Ltd

Country of Origin: the Mainland of China

Brand: Aquapower

Details of Fittings: Range of ductile iron gate valves with blue epoxy coating, EPDM coated ductile iron discs and EPDM seals. The valves are operated via a non-rising spindle headwork

with a hand wheel operating member. Maximum working pressure 16.0 bar. Maximum operating temperature 80°C. (with epoxy coating under WRAS approval no. 1906535)

Model: 3D1224

Size: 50mm, 65mm, 80mm, 100mm, 150mm, 200mm

Body Markings: AQUA POWER, DI, DN, PN & BS5163 ON BODY

WRAS Approval Number: 1802137

Installation Requirements: R001

Expiry Date: 28 February 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

General Acceptance No. B20220002



3D1224