



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(220/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

29 April 2022

**Approval of “CLA-VAL” Strainers
(General Acceptance No. B20220008)**

Your letters ref. GWL/22/0303, GWL/22/0303-1 and GWL/22/0303-2 dated 3 March 2022, 22 March 2022 and 8 April 2022 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificates and test report ref. BC-SUMMARY-2018-119 issued on 21 April 2020 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Cla-Val Europe

Country of Origin: the Mainland of China

Brand: Cla-Val

Details of Fitting:	AQUA range of in line H-strainers with flanged, epoxy coated ductile iron bodies and stainless steel mesh and EPDM O-rings. Maximum working pressure 16.0 bar. Maximum operating temperature 65°C. (with epoxy powder coating under WRAS approval no. 2202530)
Model:	AQUA 90-501
Size:	40mm, 50mm, 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm
Body Markings:	Flow arrow, size and PN rating on valve body. Cla Val, model, size and PN rating on metal data plate on flange connection
WRAS Approval Number:	1809056
Installation Requirements:	R001, R120 (Appendix A of WRAS approval letter refers)
Expiry Date:	30 September 2023

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



AQUA 90-501