



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(613/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

14 September 2022

**Approval of “HATTERSLEY” Pressure Reducing Valves
(General Acceptance No. B20220025)**

Your letters dated 25 May 2022, 11 July 2022 and 16 August 2022 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test report ref. BC-SUMMARY-2019-49 issued on 21 June 2022 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hattersley
Country of Origin: Italy
Brand: Hattersley
Details of Fittings: Copper alloy pressure reducing valve
Model: Fig.425
Size: ½", ¾", 1", 1¼", 1½", 2"



Body Markings: Hattersley & Model on operating member. Size, DN, flow arrow, CR on body.

WRAS Approval Number: 2205804

Installation Requirements: R001, R120
(Appendix A of WRAS approval letter refers)

Expiry Date: 29 December 2025

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –


“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Mable LH LAM)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Fig.425