



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(6) in WSD 3321/2024 T/J(1477/2024)

13 March 2025

**Approval of “HATTERSLEY” Strainers
(General Acceptance No. B20250003)**

Your letter dated 30 December 2024 and subsequent submissions received by this department up to 17 February 2025 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificates and test report ref. AMA11033A issued on 6 February 2025 by ETS-Testconsult Ltd comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hattersley
Country of Origin: the Mainland of China
Brand: Hattersley
Details of Fitting: Copper alloy Y-strainer
Model: Fig 817
Size: ½", ¾", 1", 1¼", 1½", 2"



Body Markings: Hattersley, Size PN Rating, ➡ on body.
 Temperature/Pressure ratings WRAS Temperature rating,
 Brand, Type & cap torque Reference on the I.D. plate.

WRAS Approval Number: 241008007

Installation Requirements: R001, R120
 (Appendix A of WRAS approval letter refers)

Expiry Date: 29 July 2026

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Fig 817