



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2025 T/J(110/2025)

26 March 2025

**Approval of “TECTITE CLASSIC” Copper Fittings
(General Acceptance No. B20250007)**

Your letters ref. Q-1512/24 and Q-1536/25 dated 12 February 2025 and 28 February 2025 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test report ref. BC-SUMMARY-2025-025 issued on 7 January 2025 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Aalberts Integrated Piping Systems Ltd

Country of Origin: UK

Brand: Tectite Classic

Details of Fittings: Copper alloy fittings with push-fit connection end

Description	Model	Size
Straight Coupling	T1/T270	15, 22, 28 (mm)



Description	Model	Size
Slip Coupling	T1S/T270S	15, 22, 28 (mm)
Straight Female Connector	T2/T270G	15x½", 22x¾", 28x1" (mm x inch)
Straight Male Connector	T3T/T243G	15x½", 22x¾", 28x1" (mm x inch)
Straight Male Connector	T3P	15x½", 22x¾" (mm x inch)
Elbow	T12/T090	15, 22, 28 (mm)
Street Elbow	T12S/T092	15, 22, 28 (mm)
Male Elbow	T13/T092G	15x½", 22x¾", 28x1" (mm x inch)
Female Elbow	T14/T090G	15x½", 22x¾", 28x1" (mm x inch)
Backplate Elbow	T15/T471G	15x½", 22x¾" (mm x inch)
Obtuse Elbow	T21/T041	15, 22, 28 (mm)
Obtuse Street Elbow	T21S/T040	15, 22, 28 (mm)
Equal Tee	T24/T130	15, 22, 28 (mm)
Tee	T25/T130	22x22x15, 28x28x22 (mm)
Tee	T26/T130	22x15x22, 28x22x28 (mm)
Tee, One End and Branch Reduced	T27/T130	22x15x15, 28x22x22 (mm)
Female Branch Tee	T30/T130G	15x15x½", 22x22x½", 22x22x¾" (mm x mm x inch)

Body Markings: Tectite, CR & size on fitting body

WRAS Approval Number: 241288002

Installation Requirements: R001
(Appendix A of WRAS approval letter refers)

Expiry Date: 31 December 2026

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



T1/T270



T1S/T270S



T2/T270G



T3T/T243G



T3P



T12/T090



T12S/T092



T13/T092G



T14/T090G



T15/T471G



T21/T041



T21S/T040



T24/T130



T25/T130



T26/T130



T27/T130



T30/T130G