



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2025 T/J(169/2025)

27 March 2025

**Approval of “ERA” Ball Valves
(General Acceptance No. B20250008F)**

Your letter received on 3 March 2025 refers.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: ERA Piping (Zhejiang) Co Ltd

Country of Origin: the Mainland of China

Brand: ERA

Details of Fitting: uPVC ball valve with grey colour

Model and Size:

Model	Size
UCB01	20mm, 25mm, 32mm, 40mm, 50mm, 63mm, 75mm, 90mm, 110mm
UTB01	20mm, 25mm, 32mm, 40mm, 50mm, 63mm, 75mm, 90mm, 110mm
USU01	20mm, 25mm, 32mm, 40mm, 50mm, 63mm, 75mm, 90mm, 110mm
UCB05	20mm, 25mm, 32mm, 40mm, 50mm, 63mm



Body Markings:

For UCB01:

ERA® and size on operating member. Size, WRAS, date of manufacture (YYYYMM) and material on body

For other models:

ERA® and size on operating member. Size, PN, WRAS, date of manufacture (YYYYMM), material and  on body

WRAS Approval Number: 2201048

Installation Requirements: R001

(Appendix A of WRAS approval letter refers)

Expiry Date:

31 December 2026

Proviso:

As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing systems.

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer
Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



UCB01



UTB01



USU01



UCB05