



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/16 Pt.1 T/J(1206)

31 August 2016

Approval of "YUE HING" Hydrant Valve

Your letter ref. WSD/AP-16082016-1 dated 16 August 2016 refers.

Having considered the test report ref. J20607 issued on 15 August 2016 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yue Hing Machine Factory Ltd.

Country of Origin: China

Brand: Yue Hing

Details of Fitting: 100mm Copper alloy twin individual control outlet fire hydrant valve

Model: Y1230

Body Marking: Logo of "Yue Hing" 100 BS5041/1
LP 201-JUN (Date of manufacture)

Expiry Date: 28 July 2021

Proviso: The fitting can only be used in fire service plumbing system.

This Authority hereby permits the use of the above fitting in fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in fire service plumbing systems.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/CS(MC)] - with soft copy only



Y1230