



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(1189)

1 September 2016

Approval of "WATERFRONT" Stop Valves

Your letters ref. L16W239 and L16W264 dated 11 August 2016 and 22 August 2016 respectively refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Waterfront	Series 909 (¾")	J20709Ar1	18 August 2016
Waterfront	Series 909 (1")	J20709Br1	18 August 2016
Waterfront	Series 909 (1¼")	J20709Cr1	18 August 2016
Waterfront	Series 909 (1½")	J20709Dr1	18 August 2016

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Taizhou Dabao Plumbing Equipment Co., Ltd.

Country of Origin: China

Brand: Waterfront

Details of Fittings: Gunmetal loose jumper stop valve

Model: Series 909

Size: ¾", 1", 1¼", 1½"

Body Markings: size → logo of "Waterfront"

Expiry Date: 7 August 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/CS(MC)] - with soft copy only



Series 909