



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/16 Pt.1 T/J(1244)

8 September 2016

Approval of "TOGA" Galvanized Steel Pipes

Your letter dated 25 August 2016 refers.

Having considered the test report ref. PMA63901 issued on 17 August 2016 by ETS-Testconsult Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jinan Mech Piping Technology Co., Ltd.

Country of Origin: China

Brand: Toga

Details of Pipes: Galvanized steel pipes; class heavy

Size: DN20, 25, 32, 40, 50, 65, 80, 100

Body Markings: TOGA BSEN10255 CLASS HEAVY
size x thickness W

Expiry Date: 15 August 2021

Proviso: The pipes can only be used in fire service plumbing system.

This Authority hereby permits the use of the above pipes in fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fire service plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/CS(MC)] - with soft copy only