



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/16 Pt.1 T/J(1272)

12 September 2016

Approval of "SHOWA-FLEX" Flexible Joints

Your letter ref. WL-16/028 dated 2 September 2016 refers.

Having considered the test report ref. 163553ST160784 issued on 1 September 2016 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Showa Valve Co., Ltd.

Country of Origin: China

Brand: Showa-Flex

Details of Fitting: Twin sphere rubber flexible joint

Model: Fig. 90

Size: DN50, 65, 80, 100, 125, 150, 200, 250

Body Markings: size in inch · mm SHOWA-FLEX
Production Month/Year

Expiry Date:

25 August 2021

Proviso: The fittings can only be used in non-potable water plumbing system.

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/CS(MC)] - with soft copy only



Fig. 90