



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/16 Pt.1 T/J(1282)

3 October 2016

Approval of "S.H." Ball Valves

Your letter dated 1 September 2016 and subsequent submission received by this department on 22 September 2016 refer.

Having considered the test report ref. 163467ST160776A issued on 14 September 2016 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shie Yu Machine Parts Industrial Co., Ltd.

Country of Origin: Taiwan

Brand: S.H.

Details of Fitting: uPVC Compact ball valve in white colour

Size: DN15, 20, 25, 32, 40, 50

Body Markings:

(S.H.) COMPACT BALL VALVE 20 – 1/2" DN15 UPVC CC100-CC200 NSF-pw

(S.H.) COMPACT BALL VALVE 25 – 3/4" DN20 U-PVC CC100-CC200 NSF-pw

(S.H.) COMPACT BALL VALVE 32 – 1" DN25 U-PVC CC100-CC200 NSF-pw

(S.H.) COMPACT BALL VALVE 40 – 1 1/4" DN32 U-PVC CC100-CC200 NSF-pw

(S.H.) COMPACT BALL VALVE 50 – 1 1/2" DN40 UPVC CC100-CC200 NSF-pw

(S.H.) COMPACT BALL VALVE 63 – 2" DN50 U-PVC CC100-CC200 NSF-pw

Expiry Date:

11 August 2021

Proviso: As the fittings has not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

